



Number	20GR0034/00	Replaces	--
Issue date	10-01-2020	Contract number	E 8090
Due date	10-01-2030	Module	B (Type testing)
Report number	181101826	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CU3826		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boiler, type(s):

**Maxi Condense PS100-AL/1-C (H-TR),
Maxi Condense PS150-AL/1-C (H-TR)**

Manufacturer

**DemirDöküm
Bozüyük, Turkey**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

www.kiwaenergy.com

GASTEC

Ronald Karel, Kiwa



Number 20GR0034/00 **Replaces** --
Issue date 10-01-2020 **Contract number** E 8090
Due date 10-01-2030 **Module** B (Type testing)
Report number 181101826 **Scope** (EU) 2016/426 (9 March 2016)
PIN 0063CU3826 **Page** 1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
DemirDöküm

Types:

Model name	Heat input CH (kW - Hi)
Maxi Condense PS100-AL/1-C (H-TR)	20 - 100
Maxi Condense PS150-AL/1-C (H-TR)	30 - 150

Model name	Appliance categories		Countries
Maxi Condense PS100-AL/1-C (H-TR)	II _{2H3P}	G20-20 mbar	Turkey
Maxi Condense PS150-AL/1-C (H-TR)		G31-37 mbar	

Model name	Appliance types	Flue installation manuals (use latest version)	Article number back flow valve with manual
Maxi Condense PS100-AL/1-C (H-TR)	B ₂₃ , B _{23P} , B ₅₃ , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₉₃	0020285895	-
Maxi Condense PS150-AL/1-C (H-TR)			